

CRS-1014

REQUIREMENTS FOR TRENCHING AND BACKFILLING BY
CUSTOMER FOR ALL 120/240 V UNDERGROUND SERVICE LATERALS
IN A JOINT ELECTRIC/GAS TRENCH INSTALLATION

THIS SPECIFICATION CONTAINS BASIC INFORMATION WHICH DEFINES PP&L'S
REQUIREMENTS FOR TRENCHING AND BACKFILLING BY CUSTOMER FOR A 120/240 VOLT
UNDERGROUND SERVICE LATERAL IN A JOINT ELECTRIC/GAS TRENCH INSTALLATION.

ALL DETAILS OF THIS SPECIFICATION SHALL BE STRICTLY FOLLOWED.
ANY DEVIATION MUST BE APPROVED BY THE PP&L DESIGNER. UNAPPROVED DEVIATIONS
ARE USUALLY COSTLY FOR THE CUSTOMER TO CORRECT AND CAN RESULT IN DELAYS
OR POSSIBLE REFUSAL TO CONNECT SERVICE.

REQUIREMENTS FOR TRENCHING AND BACKFILLING BY DEVELOPER/CUSTOMER
FOR PRIMARY AND SECONDARY IN A JOINT ELECTRIC/GAS TRENCH INSTALLATION
ARE SPECIFIED IN CUSTOMER REFERENCE SPECIFICATION CRS-1013.

SPONSOR: _____
M. PAVUK

APPROVED: _____
M A GARBER, SUPV - T&D COMPONENTS